

Advanced Ionization Smoke Detectors

Models CPD-7054 and CPD-7054D

F-70-01



A UTC Fire & Security Company

FEATURES

- Approvals/Listing
 - US and Canadian UL Listed (cULus)
 - FM Approved
 - CSFM Approved
 - NYC MEA Accepted
- Dual Ionization Chamber Technology
- Nominal Sensitivity
 - CPD-7054: 1.30% per ft. Obscuration
 - CPD-7054D: 1.00% per ft. Obscuration
- Sensitivity Measurement/Testing
 - Wireless Measurement in %/ft. Obscuration
 - Remote and Local Functional Test Capability
- Wide Range of Input Voltage 10.2 to 36.8 Vdc
- Low Current Design
- Dual Response LEDs Allow 360-degree Viewing
- Trouble Indication
- Low Profile Appearance Using Surface Mount Technology
- Electrically and Mechanically Compatible with all Fenwal Smoke and Electronic Heat Detectors and Bases
- Interchangeable 2-Wire and 4-Wire Bases
- Universal Relay Modules
- Non Polarized
- Locking Feature for Vandal Resistance
- Fine Mesh Insect Screen
- EMI and RFI Resistant

DESCRIPTION

The Fenwal Models CPD-7054 and CPD-7054D are dual chamber Ionization Smoke Detectors designed to sense both visible and invisible products of combustion. The Detectors have advanced solid-state, low-voltage, surface-mount circuitry and are designed for 2-Wire and 4-Wire installation using the appropriate Detector base. The characteristic 360-degree detector design permits smoke entry from any direction. A unique sensing chamber design permits the operation of the Models CPD-7054 and CPD-7054D in open areas with air velocities from 0 to 300 fpm and 0 to 500 fpm, respectively. The Model CPD-7054D is also suitable for duct housing applications in air velocities from 500 to 4000 fpm. The Detectors are designed for open area/duct housing applications per UL268/UL268A and may be installed in systems intended for Releasing Device Service through use of compatible Fire Alarm Control Panels.



Two red Light Emitting Diodes (LEDs) are located diametrically opposite each other so as to allow 360-degree viewing. Both LEDs continuously indicate the operating condition of the Detector. During standby, the LEDs flash once every six seconds. During alarm, both LEDs light steady at full brilliance. A double flash every six seconds indicates a detector with a sensitivity threshold outside acceptable limits. A unique gated output circuit design provides improved stability and transient suppression. Special signal processing techniques verify the presence of smoke before the detector will alarm. A fine mesh insect screen protects the chamber area and is used to avoid potential nuisance alarms. The detector head is installed into its mounting base with a simple twist-lock action. A locking feature is provided for vandal resistant security.

Table 1 lists the Technical Specifications for Models CPD-7054 and CPD-7054D Ionization Smoke Detectors.

CONTROL UNITS

The Models CPD-7054 and CPD-7054D Detectors are designed to operate with control units and releasing devices having specific voltage and current characteristics that are compatible with the detector circuitry. Both models are compatible with the Fenwal 732 control unit. The Fenwal 732 has three detection circuits which can support up to 25 detectors per circuit.

Table 1: Technical Specification

Model Number	CPD-7054	CPD-7054D
Part Number	70-540000-001	70-540000-002
Detection	Dual Ionization Chamber	Dual Ionization Chamber
Approvals	cULus, FM, CSFM, MEA-NYC, USNRC, CNSC	cULus, FM, CSFM, MEA-NYC, USNRC, CNSC
UL Compatibility I.D.	I51FE1	I51FE1
Listed Spacing	30 ft. (9.1 m) centers or 900 ft. ² (83.6 m ²)	30 ft. (9.1 m) centers or 900 ft. ² (83.6 m ²)
Radioactive Source Material Activity	Americium 241 (sealed) 0.8 µCi (29.6 kBq)	Americium 241 (sealed) 0.8 µCi (29.6 kBq)
Nominal Sensitivity	1.30% + 0.25% - 0.42% per foot Obscuration	1.00% + 0.10% - 0.12% per foot Obscuration
Standby Voltage (Vdc)		
Using 2WB:	10.2 to 36.8	10.2 to 36.8
Using 4WRB:	16.8 to 36.8	16.8 to 36.8
Maximum Current		
Standby:	70 µA	70 µA
Alarm:	100 mA	100 mA
Response Indicators		
Quantity:	2 external LEDs	2 external LEDs
Standby Condition:	One flash every 9 seconds	One flash every 9 seconds
Thermistor Trouble:	Double flash every 9 seconds	Double flash every 9 seconds
Alarm Condition:	Steady at full brilliance	Steady at full brilliance
Operating Environment		
Operating Temperature:	32° to 120°F (0° to 49°C)	32° to 120°F (0° to 49°C)
Storage Temperature:	-20° to 180°F (-29° to 82°C)	-20° to 180°F (-29° to 82°C)
Relative Humidity:	0 to 93% Non-condensing	0 to 93% Non-condensing
Air Velocity		
Open Area:	0 to 300 fpm (0 to 1.5 m/s)	0 to 500 fpm (0 to 2.5 m/s)
Duct Housing:	N/A	500 to 4000 fpm (2.5 to 20 m/s)
Altitude:	Up to 7,500 feet (2,286 m)	Up to 7,500 feet (2,286 m)
Physical Characteristics		
Material and Finish:	High-impact, flame-retardant plastic, off white	High-impact, flame-retardant plastic, off white
Weight:	35.3 oz. (110g) w/o base	35.3 oz. (110g) w/o base
Dimensions		
Detector Height:	1-3/8 in. (35 mm)	1-3/8 in. (35 mm)
Detector Diameter:	3-29/32 in. (99 mm)	3-29/32 in. (99 mm)
Base Height:	3/64 in. (11 mm)	3/64 in. (11 mm)
Base Diameter:	5-29/32 in. (150 mm)	5-29/32 in. (150 mm)

DETECTOR BASE OPTIONS

The Models CPD-7054 and CPD-7054D can be used with the detector base options and accessories in Table 2. Various base options are available to provide auxiliary relay and/or remote indication and remote test feature. The Model CPD-7054 and CPD-7054D Ionization Smoke Detectors may be interchanged with other Fenwal Series THD-705X Electronic Heat Detector and Series PSD-715X Photoelectric Smoke Detectors when using multifunction base configuration.

SPACING (OPEN AREA LOCATION)

The Models CPD-7054 and CPD-7054D Detectors are listed to be installed on maximum 30 ft. (9.1 m) centers, typically on smooth ceilings up to 15 ft. (4.6 m) high and will operate with minimum air circulation.

Resultant maximum 900 square foot (83.6 m^2) spacing may be used as a reasonable guide for comparable applications. Where special conditions exist (ceiling obstructions, high air exchange rates, etc.), reduced spacing must be used to achieve adequate protection. Computer rooms and other such installations may require spacing with a maximum of 200 ft.² (18.6 m^2) due to high air exchange rates.

Detectors should not be located in areas with excessive exhaust fumes, kitchen areas, near fireplaces or furnace rooms and within three (3) ft. (0.9 m) of air supply ducts or air diffusers.

For additional information, consult the Fenwal Automatic Fire Detection Application Engineering Manual MC-402, NFPA-72 and the local Authority Having Jurisdiction.

WIRING DIAGRAMS

For detailed wiring diagrams with Fenwal 2- and 4-wire bases, please refer Fenwal Document 06-235056-001.

INSTALLATION

Detector bases are directly mounted on the electrical junction boxes (3-inch, 3-1/2-inch and 4-inch octagonal, 3-inch round or 4-inch²) (76 mm, 89 mm, 102 mm octagonal, 76 mm round or 102 mm²) without the need for any mechanical adapter required. Refer Fenwal Document 06-235056-001 for additional details.

TESTING AND MAINTENANCE

Testing shall be performed upon installation of the detector and once a year thereafter as stated in NFPA-72 latest edition. Detector sensitivity shall be checked within one year of installation and every alternative year thereafter as stated in NFPA 72. Refer Fenwal Documents 06-236514-001 and 06-235056-001 for details on using the Infrared Wireless Sensitivity Tester Model DST-003. The tester provides direct readout in percent per foot obscuration from a distance of 15 ft.

without removing the detector from its base. A go/no-go test can be performed using a test magnet.

The recommended requirement for detector maintenance consists of an annual cleaning of dust from the detector head by using the suction of a vacuum cleaner. Cleaning programs should be geared to the individual environment in conformance with NFPA 72.



Do not attempt disassembly of the factory sealed smoke detector. This assembly is sealed for your protection and should not be opened for servicing. Opening of the detector will void its warranty.

SPARE PARTS

The Models CPD-7054 and CPD-7054D Detectors are factory repairable only and have no field serviceable spare parts. No field repair should therefore be attempted. For service, return detector head intact to Fenwal.

RADIOACTIVE MATERIAL/DISPOSAL

The Americium 241 radioactive material used is shielded by a stainless steel housing and has a maximum activity of 0.8 microcuries (29.6 kBq).

The United States Nuclear Regulatory Commission (USNRC) allows the user of Americium 241 filled smoke detectors to dispose of them without obtaining a license. Under the Code of Federal Regulations, Part 10 (10CFR), Paragraph 30.20, any person receiving, using, owning, etc., by-product material in detectors designed to protect life or property from fires or airborne hazards is automatically granted a general license which, conversely, exempts them from a specific license, thereby allowing them to both receive and dispose of smoke detectors without returning to the manufacturer.

ARCHITECT/ENGINEER SPECIFICATIONS

The contractor shall furnish and install where indicated on the plans, UL268/UL268A listed dual-chamber, Ionization Smoke Detectors, Fenwal Models CPD-7054 and CPD-7054D. Ionization Smoke Detectors containing a radioactive source of strength greater than 0.8 microcuries (29.6 kBq) shall not be acceptable. The combination detector head and twist-lock base shall be UL Listed compatible with a UL Listed fire alarm control unit. The Models CPD-7054 and CPD-7054D Ionization Smoke Detectors shall share interchangeable bases with the PSD-7157 and PSD-7157D Photoelectric Smoke Detectors and the THD-7052 and THD-7053 Heat Detectors. The Fenwal Models CPD-7054 and CPD-7054D Ionization Smoke Detectors shall have two Red LEDs located diametrically opposite each other so as to

allow 360-degree viewing. The LEDs shall continuously indicate the operating condition of the Detector. During standby, the LEDs shall flash once every six seconds. During alarm, both LEDs shall light steady at full brilliance. If the sensitivity of the detector drifts outside acceptable limits, the LEDs shall double flash every six seconds. The detector may be reset by actuating the control panel reset switch. The vandal-resistant security locking feature shall be used in those areas as indicated on the drawings. The locking feature shall be field removable when not required.

It shall be possible to measure the sensitivity of the Fenwal Models CPD-7054 and CPD-7054D Ionization Smoke Detectors from a distance of up to 15 ft. (4.6 m) without removal from the base. Measurement shall be accomplished with a wireless infrared Fenwal Sensitivity Tester (DST-003) allowing direct measurement in percent per foot obscuration. Sensitivity measurement techniques requiring wiring between the Detector-Base combination and the Tester shall not be acceptable. It shall also be possible to perform a functional test of the detector without the need for generating smoke.

The Fenwal Models CPD-7054 and CPD-7054D Ionization Smoke Detectors shall operate over an input voltage range from 10.2 to 36.8 Vdc. Voltage and RF transient suppression techniques to withstand up to 20 volt/meter shall be employed to minimize susceptibility to false alarms.

Supplementary SPDT relays, remote test, and/or remote LED alarm indicators shall be installed where indicated.

Table 2: Ordering Information

Part Number	Model	Description
Detector Heads - Ionization Smoke		
70-540000-001	CPD-7054	<i>Ionization Advanced Smoke Detector (cULus)</i>
70-540000-002	CPD-7054D	<i>Ionization Advanced Smoke Detector (cULus)</i>
Detector Heads - Photoelectric Smoke		
71-570000-001	PSD-7157	<i>Photoelectric Advanced Smoke Detector (cULus)</i>
71-570000-002	PSD-7157D	<i>Photoelectric Advanced Smoke Detector (cULus)</i>
Detector Heads - Heat		
70-520000-001	THD-7052	<i>135°F (57°C) Fixed Heat Detector, 15°F (-9°C) Rate of Rise (cULus)</i>
70-530000-001	THD-7053	<i>135°F (57°C) Fixed Heat Detector (cULus)</i>
Detector Bases		
70-501000-001	2-Wire	2-Wire Standard Base. Connects to circuit via screw terminals. (CID = FE51A)
70-501000-002	2WRLT	2-Wire Base w/ Remote LED & Test capabilities. Connects to circuit via screw terminals. Minimum Alarm Current 15 mA @ 24 Vdc. (CID = FE52A)
70-501000-005	2WRB	2-Wire Base w/ 2WRM, Remote LED & Test capabilities. Connects to circuit via pigtail leads. Minimum Alarm Current 19 mA @ 24 Vdc. (CID = FE55A)
70-501000-101	4WRB	4-Wire Base w/ 4WRM, Remote LED & Test capabilities. Connects to circuit via pigtail leads. Minimum Alarm Current 35 mA @ 24 Vdc.
70-500000-004	2WRM	Spare SPDT Relay for 2WRB Bases. Contacts rated 1.0 A, 30 Vdc/0.5 A, 125 Vac.
Detector Accessories		
06-117883-001		Test Magnet
29-116788-001		EOL Supervisory Relay
70-200000-911	RA-911	Remote Alarm Indicator
70-200000-914	RA-914	Remote Alarm Indicator with Smoke Detector Switch
70-500000-003	DST-003	<i>Advanced Handheld Wireless Smoke Detector Sensitivity Tester</i>
70-501000-003	MA-001	Mechanical Retrofit Adapter. Allows CPD-705X and PSD-715X Detectors to physically connect to Base P/Ns 70-201000-001, -002, -003, -005 & DH-22. (CID = MAFE1)

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly.
If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL, INC., Ashland, MA 01721. Telephone: (508) 881-2000.



A UTC Fire & Security Company

400 Main Street
Ashland, MA 01721
Ph: 508.881.2000
Fax: 508.881.8920
www.fenwalfire.com